

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 13-51-08216
Name of Facility: Design & Architecture
Address: 4001 NE 2 Avenue
City, Zip: Miami 33137

Correct By: Next Inspection
Re-Inspection Date: None

Type: Public School
Owner: M-DCSB Food and Nutrition
Person In Charge: Georgina Palomo Phone: (305) 573-7135

Inspection Information

Purpose: Routine
Inspection Date: 1/11/2017

Begin Time: 12:00 PM
End Time: 01:00 PM

Additional Information

FEMALES 300
MALES 270

CENSUS 570

As per section 120.695 of the Florida Statutes (FS), this form will serve as a "Notice of Non-Compliance: for any violations noted. Items marked below violate the requirements of Chapters 64E-13 and 64E-11 of the Florida Administrative Code (FAC) and must be corrected within the time period indicated in the "Results" section above. Continued operation of this facility without making these corrections is a violation of Chapter 64E-13 and 64E-11, FAC, and Chapter 381, FS. Failure to correct violations may result in an administrative fine or other legal action being initiated or continued.

Violation Markings

SCHOOL SANITATION	11. Cleanliness & Repair	22. Solid Waste
1. School Site	12. Toilet Facilities	VECTOR/VERMIN CONTROL
2. Playground Equipment	13. Separation of Sexes	23. Infestation/Control
3. Athletic Equipment	14. Fixture Ratio	24. Brush/Trash
BUILDINGS	15. Handwash Facilities	25. Water Collection/Drainage
4. Construction	16. Showers/Fixtures	SAFETY
X 5. Maintenance & Repair	17. Shower Water Temp.	26. First Aid Kit
X 6. Lighting/Foot-Candles	WATER SUPPLY	FOOD
X 7. Heating, Ventilation, A/C	18. Installed/Operated/Maintained	27. Food Insp. Rpt.
8. Natural Ventilation	X 19. Drinking Fountains	OTHER
9. Mechanical Ventilation	20. Approved Source	28.
SANITARY FACILITIES	LIQUID/SOLID WASTE	29.
10. Provided/Accessible	21. Sewage Disposal	

General Comments

No General Comments Available

Email Address(es): gpalomo@dadeschools.net;
ipalacio@dadeschools.net;
jware@dadeschools.net;
jaybolton@dadeschools.net

Inspector Signature:

Vanessa Caporaso

Client Signature:

G Palomo

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

Violations Comments

<p>Violation #5. Maintenance & Repair Repair or replace single chipped desk in 121. Plug two holes under ActivBoard computers in library. Seal ceiling windows in U haul, east side to keep them from leaking. Replace water-damaged tile in 129. CODE REFERENCE: Maintenance & Repair 64E-13.004(3)(b)(c). Buildings shall be kept clean and in good repair, free from hazardous conditions, such as loose or broken floor tiles and boards; loose moldings; loose hanging fixtures, pipes, and electric wires; and broken plaster. Furnishings and equipment shall be kept clean and in good repair, free of missing parts and hazards such as sharp edges, splinters, and protruding or rusty nails.</p>
<p>Violation #6. Lighting/Foot-Candles Replace lights in 152A and 154. CODE REFERENCE: Lighting/Foot-Candles 64E-13.004(4)(a-d). Illumination in all instructional spaces shall be designed to provide a minimum of forty (40) foot-candles glare free at normal task level. Fixtures shall be so located that there will be uniform (within ten (10) foot-candles) illumination suitable for the activities conducted therein. All required illumination shall be designed so that the failure of any single unit, such as the burning out of an electric bulb will not leave any occupied area or means of egress in darkness. Illumination of chalkboards and other visual aids shall be designed to eliminate glare and shadows.</p>
<p>Violation #7. Heating, Ventilation, A/C Dust ceiling vents in library. CODE REFERENCE: Heating, Ventilation, A/C 64E-13.004(5)(a)(c). Permanent type school buildings and additions to school buildings shall be provided with heating facilities. Heating facilities shall be designed to heat to a temperature of not less than 70°F., instructional rooms, locker rooms and cafeterias; and 65°F., toilets and activities rooms, such as gymnasiums and shops.</p>
<p>Violation #19. Drinking Fountains Repair left water fountain next to custodial 141. CODE REFERENCE: Drinking Fountains 64E-13.004(7)(b). Drinking fountains of an approved, sanitary slant jet type shall be provided in the ratio specified in the local building code or Chapter 64E-10, F.A.C. In no case shall fountains be located in any toilet room.</p>

Inspection Conducted By: Vanessa Capriglione (115742)
Inspector Contact Number: Work: (305) 623-3500 ex. 23722
Print Client Name:
Date: 1/11/2017

Inspector Signature:

Vanessa Capriglione

Client Signature:

A. Palermo